

VOC Content Test Certificate

12th November 2012

Manufacturer: Construction Technologies Australia Pty Ltd (70 Platinum Street, Crestmead Queensland 4132)

Sample Description: PROMAXSTIK micro cement based mastic ceramic tile adhesive

Date Tested: February 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p>PROMAXSTIK</p>
<p>Ceramic Tile Adhesive 65 grams per Litre material</p>	<p>8 grams per Litre as VOC content material</p>
<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p>PROMAXSTIK</p>
<p>Ceramic Tile Adhesive 65 grams per Litre material</p>	<p>8 grams per Litre as VOC content material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0902-04